

Instructions: Complete this form once the home is completed and ready for evaluation.

Email this form to newhomes@efficiencymb.ca.

Note: Efficiency Manitoba cannot issue any Rebate payment unless all forms have been completed and submitted.

Failure to do so will delay payment.

Applicant information

Full legal name (name of organization, if applicable)			
Contact person name	Phone no.	Email	
Address of energy efficient home		City/town	Province Postal code
ACTUAL OR ESTIMATED COMPLETED DATE	yyyy mm dd	Approved New Homes Program application no.	

Prescriptive Path Technical Standard

Note: the R-values listed below are effective, not nominal values.

1. Attic insulation of R-58 effective
2. Exterior above-grade wall insulation of R-17 effective
3. Basement insulation of R-18 effective
4. Header (rim joist) insulation of R-18 effective
5. Triple pane, low-e argon windows with low conductivity frame and spacer
6. High efficiency heat recovery ventilation (HRV), rated SRE 65% or better at -25°C
7. Advanced HRV controls*
8. LED lighting throughout
9. Tested air tightness of not more than 1.5 air changes per hour at 50Pa

10. A minimum of two upgrades from the list below:

- Attic hatch gaskets and anchors
- Exterior insulation at rim joist
- Thermally broken door sills
- Orientation optimized low-e window coatings
- Slab edge thermal break (min. 1" rigid insulation between footing and slab or 2' wide 'skirt' over footing, detailed in drawings)
- Solar-ready trusses and wiring chase

*Advanced HRV controls having the ability to operate the HRV in standby mode (no low speed fan) or intermittent operation (20 mins per hour) and still run if required by the dehumidistat or the bathroom controls. Controls integrated into smart thermostats are eligible if shown to be operating the HRV at the time of completion evaluation.

Applicant statement

1. I certify that this home was built in accordance with the plans submitted at time of initial application to the New Homes Program, and as the Prescriptive Path Technical Standard.
2. I give permission for the designated program Evaluator to contact me in order to schedule an evaluation appointment for the home including verification, blower door testing, and determination of Rebate.
3. I authorize Efficiency Manitoba to release the Rebate to the payee named in the cheque payment information box on the Prescriptive Path Application and Agreement.

Signed by	yyyy mm dd	Print name (first and last name)
-----------	------------	----------------------------------

EFFICIENCY MANITOBA USE ONLY

DATE RECEIVED	yyyy mm dd	DATE ADDED TO SCHEDULER	yyyy mm dd	DATE OF EVALUATION	yyyy mm dd
Air tightness result			Final performance level		
ACH		<input type="checkbox"/> Pass <input type="checkbox"/> Fail	SOC		% HOC %
Approved by (Program Representative)					yyyy mm dd
Comments					

